

**Date of Issue:** August 22, 1997

**Affected Publication:** API Standard 598, *Valve Inspection and Testing*, 7th Edition, October 1996

## ERRATA

*Page 4, Table 2--Shell Test Pressure, the last entry in the column labeled "Class:"*

Correct the numbers "155 - 2500" to read "1500 - 2500"

*Page 4, Table 4--Duration of Required Test Pressure, the last entry in the column labeled "Valve Size (NPS)":*

The number 14 should be preceded by the symbol  $\geq$ .

*Page 5, Table 5--Maximum Allowable Leakage Rates for Closure Tests, the last entry in the column labeled "Valve Size (NPS)":*

The number 14 should be preceded by the symbol  $\geq$ .

*Table 5, footnote a, change to read as follows:*

For the liquid test, 1 milliliter is considered equivalent to 16 drops.

# Valve Inspection and Testing

API STANDARD 598  
SEVENTH EDITION, OCTOBER 1996



# Valve Inspection and Testing

**Manufacturing, Distribution and Marketing Department**

**API STANDARD 598**

**SEVENTH EDITION, October 1996**



## SPECIAL NOTES

API publications necessarily address problems of a general nature. With respect to particular circumstances, local, state, and federal laws and regulations should be reviewed.

API is not undertaking to meet the duties of employers, manufacturers, or suppliers to warn and properly train and equip their employees, and others exposed, concerning health and safety risks and precautions, nor undertaking their obligations under local, state, or federal laws.

Information concerning safety and health risks and proper precautions with respect to particular materials and conditions should be obtained from the employer, the manufacturer or supplier of that material, or the material safety data sheet.

Nothing contained in any API publication is to be construed as granting any right, by implication or otherwise, for the manufacture, sale, or use of any method, apparatus, or product covered by letters patent. Neither should anything contained in the publication be construed as insuring anyone against liability for infringement of letters patent.

Generally, API standards are reviewed and revised, reaffirmed, or withdrawn at least every five years. Sometimes a one-time extension of up to two years will be added to this review cycle. This publication will no longer be in effect five years after its publication date as an operative API standard or, where an extension has been granted, upon republication. Status of the publication can be ascertained from the API Authoring Department [telephone (202) 682-8000]. A catalog of API publications and materials is published annually and updated quarterly by API, 1220 L Street, N.W., Washington, D.C. 20005.

This document was produced under API standardization procedures that ensure appropriate notification and participation in the developmental process and is designated as an API standard. Questions concerning the interpretation of the content of this standard or comments and questions concerning the procedures under which this standard was developed should be directed in writing to the director of the Authoring Department (shown on the title page of this document), American Petroleum Institute, 1220 L Street, N.W., Washington, D.C. 20005.

API publications may be used by anyone desiring to do so. Every effort has been made by the Institute to assure the accuracy and reliability of the data contained in them; however, the Institute makes no representation, warranty, or guarantee in connection with this publication and hereby expressly disclaims any liability or responsibility for loss or damage resulting from its use or for the violation of any federal, state, or municipal regulation with which this publication may conflict.

API standards are published to facilitate the broad availability of proven, sound engineering and operating practices. These standards are not intended to obviate the need for applying sound engineering judgment regarding when and where these standards should be utilized. The formulation and publication of API standards is not intended in any way to inhibit anyone from using any other practices.

Any manufacturer marking equipment or materials in conformance with the marking requirements of an API standard is solely responsible for complying with all the applicable requirements of that standard. API does not represent, warrant, or guarantee that such products do in fact conform to the applicable API standard.

*All rights reserved. No part of this work may be reproduced, stored in a retrieval system, or transmitted by any means, electronic, mechanical, photocopying, recording, or otherwise, without prior written permission from the publisher. Contact the Publisher, API Publishing Services, 1220 L Street, N.W., Washington, D.C. 20005.*

Copyright © 1996 American Petroleum Institute

## FOREWORD

API publications may be used by anyone desiring to do so. Every effort has been made by the Institute to assure the accuracy and reliability of the data contained in them; however, the Institute makes no representation, warranty, or guarantee in connection with this publication and hereby expressly disclaims any liability or responsibility for loss or damage resulting from its use or for the violation of any federal, state, or municipal regulation with which this publication may conflict.

Suggested revisions are invited and should be submitted to the director of the Manufacturing, Distribution and Marketing Department, American Petroleum Institute, 1220 L Street, N.W., Washington, D.C. 20005

## NOTES TO PURCHASER

1. If required, the following will be specified in the purchase order:
  - a. Inspection by the purchaser at the valve manufacturer's plant (see 2.1).
  - b. Inspection by the purchaser outside the valve manufacturer's plant (see 2.2).
  - c. Address for inspection notices (see 2.3).
  - d. Any supplementary examination required (see 2.6).
  - e. Type of backseat test (see 3.3.2).
  - f. High-pressure closure test (see 3.4).
  - g. High-pressure pneumatic shell test (see 3.5).
  - h. Test fluid temperature for low temperature valves (see 3.6.2).
  - i. Use of a wetting agent in the test water (see 3.6.4).
  - j. Certificate of compliance (see 5.1).
2. If this standard is used for valves not covered by this standard, the purchaser will specify the extent to which the standard is to be applied.

## CONTENTS

	Page
NOTES TO PURCHASER .....	iv
SECTION 1—GENERAL .....	1
1.1 Scope .....	1
1.2 Referenced Publications .....	1
SECTION 2—INSPECTION, EXAMINATION, AND SUPPLEMENTARY EXAMINATION .....	1
2.1 Inspection at the Valve Manufacturer's Plant .....	1
2.2 Inspection Outside the Valve Manufacturer's Plant .....	1
2.3 Inspection Notice .....	2
2.4 Extent of Inspection .....	2
2.5 Examination .....	2
2.6 Supplementary Examination .....	2
SECTION 3—PRESSURE TESTS .....	2
3.1 Test Location .....	2
3.2 Test Equipment .....	2
3.3 Tests Required .....	2
3.4 High-Pressure Closure Test .....	2
3.5 High-Pressure Pneumatic Shell Test .....	2
3.6 Test Fluid .....	3
3.7 Test Pressures .....	3
3.8 Test Duration .....	3
3.9 Test Leakage .....	4
SECTION 4—PRESSURE TEST PROCEDURES .....	5
4.1 General .....	5
4.2 Shell Test .....	5
4.3 Backseat Test .....	5
4.4 Low-Pressure Closure Test .....	6
4.5 High-Pressure Closure Test .....	6
SECTION 5—VALVE CERTIFICATION AND RETESTING .....	6
5.1 Certificate of Compliance .....	6
5.2 Retesting .....	6
 Tables	
1A—Pressure Tests (See 3.3.3) .....	3
1B—Pressure Tests (See 3.3.4) .....	3
2—Shell Test Pressure .....	4
3—Other Shell Test Pressure .....	4
4—Duration of Required Test Pressure .....	4
5—Maximum Allowable Leakage Rates for Closure Tests .....	5

## Valve Inspection and Testing

### SECTION 1—GENERAL

#### 1.1 Scope

**1.1.1** This standard covers inspection, examination, supplementary examinations, and pressure test requirements for resilient-seated, nonmetallic-seated (for example, ceramic), and metal-to-metal-seated valves of the gate, globe, plug, ball, check, butterfly types. Resilient seats are considered to be:

- a. soft seats, both solid and semisolid grease type (for example, lubricated plug).
- b. combination soft and metal seats.
- c. any other type valve designed to meet resilient seat leakage rates as specified in Table 5.

API Standard 598 supplements the API standards that reference it, but API Standard 598 may also be applied to other types of valves by agreement between the purchaser and the valve manufacturer.

**1.1.2** The inspection requirements pertain to examinations and testing by the manufacturer and any supplementary examinations that the purchaser may require at the valve manufacturer's plant. The test requirements cover both required and optional pressure tests at the valve manufacturer's plant.

**1.1.3** The following tests and examinations are specified in this standard:

- a. Shell test.
- b. Backseat test.
- c. Low-pressure closure test.
- d. High-pressure closure test.
- e. Visual examination of castings.
- f. High-pressure pneumatic shell test.

#### 1.2 Referenced Publications

**1.2.1** The most recent editions of the following standards, codes, and specifications are cited in this standard:

##### ASME<sup>1</sup>

- B1.20.1 *Pipe Threads, General Purpose (Inch)*
- B16.11 *Forged Steel Fittings, Socket-Welding and Threaded*
- B16.34 *Valves—Flanged, Threaded, and Welding End*

##### MSS<sup>2</sup>

- SP-55 *Quality Standard for Steel Castings for Valves, Flanges and Fittings and Other Piping Components—Visual Method*
- SP-91 *Guidelines for Manual Operation of Valves*

**1.2.2** This standard supplements the following API valve standards:

##### API

- Std 594 *Check Valves: Wafer, Wafer Lug, and Double Flanged Type*
- Std 599 *Steel and Ductile Iron Plug Valves*
- Std 600 *Steel Gate Valves—Flanged and Butt-welding Ends, Bolted and Pressure Seal Bonnets*
- Std 602 *Compact Steel Gate Valves—Flanged, Threaded, Welding and Extended-Body Ends*
- Std 603 *Class 150 Cast, Corrosion-Resistant, Flanged-End Gate Valves*
- Std 608 *Metal Ball Valves—Flanged, Threaded and Welding Ends*
- Std 609 *Butterfly Valves: Double Flanged, Lug- and Wafer-Type*

### SECTION 2—INSPECTION, EXAMINATION, AND SUPPLEMENTARY EXAMINATION

#### 2.1 Inspection at the Valve Manufacturer's Plant

The purchaser will specify in the purchase order the intention to inspect valves and witness tests and examinations at the valve manufacturer's plant. The purchaser's inspector shall have free access to any part of the plant concerned with manufacture of the valves whenever work on the order is under way.

#### 2.2 Inspection Outside the Valve Manufacturer's Plant

When the purchaser specifies that the inspection will include shell components manufactured at locations other than the valve manufacturer's plant, these components shall be subject to the purchaser's inspection at the location where they are manufactured.

<sup>1</sup>American Society of Mechanical Engineers, 345 East 47th Street, New York, New York 10017.

<sup>2</sup>Manufacturers Standardization Society of the Valve and Fittings Industry, Inc., 127 Park Street, N.E., Vienna, Virginia 22180



## 2.3 Inspection Notice

When inspection by the purchaser is specified, the valve manufacturer shall notify the purchaser five working days before the required valve testing and any specified supplementary inspections or examinations, addressing the notice as stated in the purchase order. The valve manufacturer also shall give the purchaser five working days' notice of where and when shell components manufactured outside the valve manufacturer's plant may be inspected, if such inspection is required.

## 2.4 Extent of Inspection

The extent of inspection may be specified in the purchase order and, unless otherwise indicated, shall be limited to the following:

- a. Inspection of the valve during assembly to ensure compliance with the specifications of the purchase order. Inspection may include the use of specified nondestructive methods.
- b. Witnessing the required and specified optional pressure tests and examinations.
- c. Witnessing any supplementary examinations (see 2.6).
- d. Review of mill records and nondestructive examination records (including specified radiographs).

## 2.5 Examination

**2.5.1** A visual examination shall be performed by the valve manufacturer of all castings of bodies, bonnets, covers, and closure elements to ensure conformance with MSS SP-55.

**2.5.2** The valve manufacturer shall examine each valve to assure compliance with this standard and the referenced purchase specification (for example, API Standard 600; see 1.2.2).

**2.5.3** All examinations shall be performed in accordance with written procedures that comply with the applicable standards.

## 2.6 Supplementary Examination

Supplementary types of examination are required only if specified in the purchase order and only to the extent specified. Magnetic particle, radiographic, liquid penetrant, and ultrasonic examination of steel castings or forgings shall be in accordance with Part 8 of ASME B16.34 or with the purchaser's own procedures and acceptance criteria, if so specified. These examinations shall be made by the valve manufacturer subject to witnessing by the purchaser's inspector.

# SECTION 3—PRESSURE TESTS

## 3.1 Test Location

Pressure tests shall be performed by the valve manufacturer at the valve manufacturer's plant.

## 3.2 Test Equipment

The equipment used by the valve manufacturer to perform the required pressure tests shall not apply external forces that affect seat leakage. If an end-clamping test fixture is used, the valve manufacturer shall be able to demonstrate that the test fixture does not affect the seat-sealing capability of the valve being tested. End-clamping is allowed for valves designed to function between mating flanges, such as wafer check and wafer butterfly valves.

## 3.3 Tests Required

**3.3.1** The pressure tests listed in Tables 1-A or 1-B shall be performed on each valve in accordance with written procedures that comply with this standard.

**3.3.2** At the manufacturer's option, the backseat test for valves that have the backseat feature may be either a high-pressure or a low-pressure test unless stated otherwise in the purchase order.

**3.3.3** Valves NPS 4 and smaller having pressure ratings up to and including ASME Class 1500 and valves larger than NPS 4 having pressure ratings up to and including ASME Class 600 shall be tested in accordance with Table 1-A.

**3.3.4** Valves NPS 4 and smaller having pressure ratings greater than ASME Class 1500 and valves larger than NPS 4 having pressure ratings greater than ASME Class 600 shall be tested in accordance with Table 1-B.

## 3.4 High-Pressure Closure Test

The high-pressure closure test is required for several valve types, as shown in Tables 1-A and 1-B. For the valve types for which, according to Tables 1-A and 1-B, the high-pressure closure test is optional, the valves are still required to be able to pass the test (as a test of the design of the valve closure structure).

## 3.5 High-Pressure Pneumatic Shell Test

When specified by the purchase order, a high-pressure pneumatic shell test shall be performed. This test shall be performed after the hydrostatic shell test, using appropriate safety precautions. The pneumatic shell test pressure shall be 110 percent of

Table 1-A—Pressure Tests (See 3.3.3)

Test Description	Valve Type					
	Gate	Globe	Plug	Check	Floating Ball	Butterfly and Trunnion-Mounted Ball
Shell	Required	Required	Required	Required	Required	Required
Backseat <sup>a</sup>	Required	Required	NA	NA	NA	NA
Low-pressure closure	Required	Optional	Required <sup>b</sup>	Alternative <sup>c</sup>	Required	Required
High-pressure closure <sup>d</sup>	Optional	Required <sup>e</sup>	Optional <sup>b</sup>	Required	Optional	Optional

Note: NA = Not applicable.

<sup>a</sup>The backseat test is required for all valves, except for bellows seal valves, that have the backseat feature.

<sup>b</sup>For lubricated plug valves, the high-pressure closure test is mandatory and the low-pressure closure test is optional.

<sup>c</sup>If agreed to by the purchaser, the valve manufacturer may use a low-pressure closure test instead of the high-pressure closure test.

<sup>d</sup>The high-pressure closure test of resilient-seated valves may degrade subsequent sealing performance in low-pressure service.

<sup>e</sup>For power-operated globe valves, the high-pressure closure test shall be performed at 110 percent of the design differential pressure used for sizing the power operator.

Table 1-B—Pressure Tests (See 3.3.4)

Test Description	Valve Type					
	Gate	Globe	Plug	Check	Floating Ball	Butterfly and Trunnion-Mounted Ball
Shell	Required	Required	Required	Required	Required	Required
Backseat <sup>a</sup>	Required	Required	NA	NA	NA	NA
Low-pressure closure	Optional	Optional	Optional	Alternative <sup>b</sup>	Required	Optional
High-pressure closure <sup>c</sup>	Required	Required <sup>d</sup>	Required	Required	Optional	Required

Note: NA = Not applicable.

<sup>a</sup>The backseat test is required for all valves, except for bellows seal valves, that have the backseat feature.

<sup>b</sup>If agreed to by the purchaser, the valve manufacturer may use a low-pressure closure test instead of the high-pressure closure test.

<sup>c</sup>The high-pressure closure test of resilient-seated valves may degrade subsequent sealing performance in low-pressure service.

<sup>d</sup>For power-operated globe valves, the high-pressure closure test shall be performed at 110 percent of the design differential pressure used for sizing the power operator.

the maximum allowable pressure at 100°F (38°C) or as specified in the purchase order. Visible leakage is not allowed.

## 3.6 Test Fluid

**3.6.1** For shell, high-pressure backseat, and high-pressure closure tests, the test fluid shall be air, inert gas, kerosene, water, or a noncorrosive liquid with a viscosity not higher than that of water. The test fluid temperature shall not exceed 125°F (52°C). The test fluid temperature may be specified in the purchase order for low-temperature valves.

**3.6.2** For the low-pressure closure and low-pressure backseat tests, the test fluid shall be air or inert gas.

**3.6.3** When air or gas is used for closure, shell, or backseat tests, the valve manufacturer shall be capable of demonstrating the adequacy of the method of leakage detection.

**3.6.4** Water used for any test may contain a water-soluble oil or a rust inhibitor. When specified by the purchaser, a wetting agent shall be included in the water. For testing of austenitic stainless steel valves, water with chloride content not exceeding 100 parts per million shall be used. The valve manufacturer shall be able to document the chloride content.

## 3.7 Test Pressures

**3.7.1** The shell test pressure shall be in accordance with Table 2.

**3.7.2** Other test pressures shall be in accordance with Table 3.

## 3.8 Test Duration

For each type of test, the required test pressure shall be maintained for at least the minimum time specified in Table 4.

### 3.9 Test Leakage

**3.9.1** For shell and backseat tests, no visible leakage is permitted. If the test fluid is a liquid, there shall be no visible evidence of drops or wetting of the external surfaces (no visible leakage through the body, body liner, if any, and body-to-bonnet joint and no structural damage). If the test fluid is air or gas, no leakage shall be revealed by the established detection method.

**3.9.2** For both the low-pressure closure test and the high-pressure closure test, visual evidence of leakage through the disk, behind the seat rings, or past the shaft seals (of valves that have this feature) is not permitted and structural damage is not permitted. (Plastic deformation of resilient seats and seals is not considered structural damage.) The allowable rate for leakage of test fluid past the seats, for the duration of the tests, is listed in Table 5.

Table 2—Shell Test Pressure

Valve Type	Class	Shell Test Pressure (minimum)	
		Pounds per Square Inch Gauge	Bar
Ductile iron	150	400	26
	300	975	66
Cast iron NPS 2-12 NPS 14-48	125	350	25
		265	19
Cast iron NPS 2-12 NPS 14-24	250	875	61
		525	37
Steel			
	Flanged and butt-weld	150-2500	a
	Screwed and socket-weld	800	b
		155-2500	a

<sup>a</sup>Per ASME B16.34.

<sup>b</sup>For Class 800 valves, the shell test pressure shall be 1½ times the pressure rating at 100°F (38°C), rounded off to the next higher increment of 25 pounds per square inch gauge (or 1 bar) (see Table 2 of API Standard 602).

Table 3—Other Test Pressures

Test	Minimum Test Pressure	
	Pounds per Square Inch Gauge	Bar
Valves Except Butterfly and Check		
High-pressure closure and backseat <sup>a</sup>	<sup>b</sup>	
Low-pressure closure and backseat <sup>a</sup>	60-100	4-7
Butterfly Valve		
High-pressure closure	<sup>c</sup>	
Low-pressure closure	60-100	4-7
Check Valve		
High-pressure closure		
Class 125 (cast iron)		
NPS 2-12	200	14
NPS 14-48	150	11
Class 250 (cast iron)		
NPS 2-12	500	35
NPS 14-24	300	21
Class 150 (ductile iron)	250	17
Class 300 (ductile iron)	640	44
Carbon, alloy, stainless steel, and special alloys	<sup>b</sup>	—
Low-pressure closure (see Tables 1-A and 1-B)	60-100	4-7

<sup>a</sup>The backseat test is required for all valves that have this feature.

<sup>b</sup>110 percent of maximum allowable pressure at 100°F (38°C) in accordance with the applicable purchase specification.

<sup>c</sup>110 percent of design differential pressure at 100°F (38°C) in accordance with the applicable purchase specification.

Table 4—Duration of Required Test Pressure

Valve Size (NPS)	Minimum Test Duration (seconds) <sup>a</sup>				
	Shell		Backseat	Closure	
	Check Valves (API Std 594)	Other Valves		Check Valves (API Std 594)	Other valves
≤ 2	60	15	15	60	15
2 ½-6	60	60	60	60	60
8-12	60	120	60	60	120
≤ 14	120	300	60	120	120

<sup>a</sup>The test duration is the period of inspection after the valve is fully prepared and is under full pressure.

Table 5—Maximum Allowable Leakage Rates for Closure Tests

Valve Size (NPS)	All Resilient- Seated valves <sup>b</sup>	All Metal-Seated Valves Except Check		Metal-Seated Check Valves	
		Liquid Test <sup>a</sup> (drops per minute)	Gas Test (bubbles per minute)	Liquid Test	Gas Test
≤ 2	0	0 <sup>b</sup>	0 <sup>b</sup>	c	d
2 1/2–6	0	12	24	c	d
8–12	0	20	40	c	d
≤ 14 <sup>c</sup>	0	28	56	c	d

<sup>a</sup>For the liquid test, 1 millimeter is considered equivalent to 16 drops.

<sup>b</sup>There shall be no leakage for the minimum specified test duration (see Table 4). For liquid test, 0 drop means no visible leakage per minimum specified test duration. For gas test, 0 bubble means less than 1 bubble per minimum specified test duration.

<sup>c</sup>The maximum permissible leakage rate shall be 0.18 cubic inch (3 cubic centimeters) per minute per inch of nominal pipe size.

<sup>d</sup>The maximum permissible leakage rate shall be 1.5 standard cubic feet (0.042 cubic meter) of gas per hour per inch of nominal pipe size.

<sup>e</sup>For check valves larger than NPS 24, the allowable leakage rate shall be per agreement between purchaser and manufacturer.

When volumetric devices are used to measure leakage, they shall be calibrated to yield results equivalent to the units per minute listed in Table 5. Volumetric devices shall be calibrated with the same test fluid and at the same temperature as used for the production tests.

**3.9.3** The allowable leakage rates for closure tests of valves with nonmetallic (for example, ceramic) seat materials shall be equal to that specified in Table 5 for a metal-seated valve of equivalent size and type.

## SECTION 4—PRESSURE TEST PROCEDURES

### 4.1 General

**4.1.1** Valves designed to permit emergency or supplemental introduction of an injectable sealant to the seat or packing area shall be tested with the injection system empty and not in use, except for lubricated plug valves.

**4.1.2** When a liquid is used as the test fluid, the valve shall be essentially free from air during the test.

**4.1.3** Required protective coatings, such as paint, which may mask surface defects, shall not be applied to any surface before inspection or pressure testing. (Phosphatizing and similar chemical conversion processes used to protect valve surfaces are acceptable even if applied before the tests, provided that they will not seal off porosity.)

**4.1.4** When closure testing gate, plug, and ball valves, the valve manufacturer shall use a method of testing seat leakage that fills and pressurizes the body cavity between the seats and the bonnet area, as applicable, with the test fluid. This will ensure that no seat leakage can escape detection because of gradual filling of these volumes during the test period.

**4.1.5** When closure testing valves, the valve manufacturer's test procedure shall ensure that excessive force is not used to close the valve. The applied force may be determined from the appropriate figures in MSS SP-91, but in any case shall not exceed the values published by the valve manufacturer.

### 4.2 Shell Test

Except as provided in 4.3.2, the shell test shall be performed by applying the pressure inside the assembled valve with the valve ends closed, the valve partially open, and any packing gland tight enough to maintain the test pressure, thereby, except for bellows seal valves, testing the stuffing box. Nonadjustable shaft seals (O rings, single rings, and the like) shall not leak during the shell test.

### 4.3 Backseat Test

**4.3.1** The backseat test is required for all valves, except for bellows seal valves, that have the backseat feature and shall be performed by applying pressure inside the assembled valve with the valve ends closed, the valve fully open, and the packing gland loose. The backseat test may be performed immediately after the shell test, and all packing glands shall be retightened after the backseat test. The successful completion of the backseat test shall not be construed as a recommendation by the valve manufacturer that, while the valve is pressurized, the valve stuffing box may be repacked or the packing may be replaced.

**4.3.2** Upon agreement between the purchaser and the valve manufacturer, the backseat test may be combined with the shell test when volumetric devices are used to monitor leakage from the shell and backseat. When tested by this method, the packing shall be loose. The manufacturer shall be responsible for demonstrating that the packing will not leak at the valve's rated pressure at 100°F (38°C).

## 4.4 Low-Pressure Closure Test

**4.4.1** The low-pressure closure test shall be performed with the sealing surfaces clean and free from oil, grease, and sealant. If necessary to prevent galling, the sealing surfaces may be coated with a film of oil that is not heavier than kerosene. This requirement does not apply to a valve that uses a lubricant as its primary seal (for example, lubricated plug valves).

**4.4.2** The low-pressure closure test shall be made in accordance with one of the following procedures, as applicable:

a. For a valve (other than a double block-and-bleed valve or globe valve) designed to close against pressure from both directions, the pressure shall be applied successively to each side of the closed valve with the other side open to the atmosphere to check for leakage at the atmospheric side of the closure. For a globe valve, pressure shall be applied in one direction with the pressure applied under the disk.

For a valve designed to close against pressure from one direction only and so marked, the pressure shall be applied on the pressure side of the valve only. For a check valve, the pressure shall be applied on the downstream side.

Any leakage at the seat, behind the seat ring, or through the disk on the open side of the valve shall be detected when bubbles are observed coming from the closure (disk, seat, and seat ring), which is either covered with water or coated with a soap or similar solution. As an alternative, a displacement measuring device may be used, provided that the detectable leakage rate is equivalent to that given in Table 5, and the device has been accepted by agreement between the purchaser and the manufacturer. Bubbler testing, when used for valves larger than NPS 2, shall only be acceptable when agreed to by the purchaser.

b. For a double block-and-bleed valve, the pressure shall be applied successively to each side of the closure through the

valve port. Leakage into the body cavity between the seats shall be checked at the packing chamber (with no packing present) or through observation at a tapped opening between the seats. Valves shall be tested with the stem in the vertical upright position. Leakage from the seats shall not exceed rates shown in Table 5.

Note: Trapping the test air or gas in the body cavity between the seats of a one-piece (solid or flexible) wedge gate valve and subsequently covering the seats with water or coating them with soap or a similar solution does not constitute an acceptable low-pressure closure test.

**4.4.3** If a tapped connection in the body cavity is made to permit testing procedures described in 4.4.2.b, the connection shall not exceed NPS 1/2 in accordance with ASME B1.20.1. The connection shall be fitted before shipment with a solid pipe plug (in accordance with ASME B16.11) with a material composition equivalent to that of the valve shell.

**4.4.4** A closure test is required in only one direction for butterfly valves furnished with encapsulation or resilient internal liners and designed for use with Class 125 or Class 150 flanges (API 609 Category A valves). For other resilient-seated butterfly valves (API 609 Category B valves), the closure test is required in both directions. For valves with a preferred flow direction, the closure test in the non-preferred direction shall be based on the reduced differential pressure rating in that direction.

## 4.5 High-Pressure Closure Test

**4.5.1** The procedure for the high-pressure closure test shall be the same as the procedure for the low-pressure closure test except that, in the case of a liquid test, leakage shall be detected when drops, not bubbles as described in 4.4.2.a, are observed.

# SECTION 5—VALVE CERTIFICATION AND RETESTING

## 5.1 Certificate of Compliance

When specified in the purchase order, the valve manufacturer shall submit to the purchaser a certificate of compliance with the purchase order.

## 5.2 Retesting

A completed valve is not required to be retested unless inspection by the purchaser is specified in the purchase

order. This retesting may be waived by the purchaser's inspector upon written certification by the manufacturer that the valve has been inspected, tested, and examined for conformance with the requirements of this standard. Painted valves need not have paint removed for retesting. Stored valves shall be commercially cleaned before retesting and before shipment.

Additional copies available from API Publications and Distribution:  
(202) 682-8375

Information about API Publications, Programs and Services is  
available on the World Wide Web at: <http://www.api.org>



**American  
Petroleum  
Institute**

1220 L Street, Northwest  
Washington, D.C. 20005-4070  
202-682-8000

Order No. C59807